

Test report

KB 85 – B1 additional test (150 - 2x150 mm²)

Report Nr.: 240507

Test specifications

Test object : Single core branch joint 24 kV
Type : LoviSil KB85
U₀ / U (U_m) : 12 / 20 (24) kV
Rated cross-section range : 95 – 240 mm²
Manufacturer : Lovink Enertech B.V.

Test period : 11-03-2024/26-04-2024
Test location : Terborg, The Netherlands

Relevant Normative Documents

NEN-HD 629-1S3_2019 Table 10

Test performed

Type test following NEN-HD 629-1S3_2019, Table 10.

Test result

The joint meets the requirements of the standard NEN-HD 629-1S3_2019, Table 10

Author:

Hassan Azhar

Development Engineer

Terborg, date 

Checked by:

Johann Conradie

Development Engineer

Terborg, 23-05-2024



Approved:

Dennis Bergsma

Manager Engineering & Development

Terborg, 23-05-2024

