

Test Report

MK125 Extended 500mm²
Report Nr.: 20802

Test specifications

Test object : 36kV straight joint
Type : LoviSil MK125
U₀ / U (U_m) : 18 / 30 (36) kV
Rated cross-section range : Three core Poly 500mm²

Manufacturer : Lovink Enertech b.v.
Test period : 10-02-2020 / 17-02-2020
Test location : Terborg, The Netherlands

Relevant Normative Documents

CENELEC HD 629.1 S2:2006 Table 10

Test performed

Type test following CENELEC HD 629.1 S2:2006, Table 10

Test result

The joint meets the requirements conform standard HD 629.1 S2:2006

Author:

Marco van Helmond

Test engineer

Terborg, 17-02-2020



Control engineer

Johann Conradie

Development engineer

Terborg, 17-02-2020



Accepted:

Dennis Bergsma

Product Development Manager

