



## Test Certificate No. 2007-158

Test object: 24kV Branch Joint for Polymeric Insulated Cables ,  
Type "LOVISIL KB 95"  
Drawing No. 0802-00 A4 dated 22.02.2008

Manufacturer: Lovink Enertech b.v., Lovinkweg 3,  
NL – 7060 AC Terborg

Test: Type Test according HD 629.2 S2 2006, Table 4,  
Test sequence B1.

Place of Test Institut für Elektroenergiesysteme und Hochspannungstechnik  
Universität Karlsruhe  
Engesserstr. 11  
76131 Karlsruhe

Test Date: Mounting: 26.11. – 30.11.2007  
Electrical Tests: 03.12.2007 – 07.02.2008

Test engineers: Dr.-Ing. B. Hoferer  
Dr.-Ing. R. Badent

Results: **All Tests was passed successfully**

Karlsruhe, 07.11.2008

Dr.-Ing. Rainer Badent  
Head of Department  
"High-Voltage Dielectric Testing"