

Test report

M105 1000mm² Additional test

Report Nr.: 18772

Test specifications

Test object : 24 KV Straight joint
Type : Lovisil M105
U₀ / U (U_m) : 12/20 (24) kV
Rated cross-section range : Single core poly 1000mm²/
Single core poly 1000mm²
Manufacturer : Lovink Enertech B.V.

Test period : 05-03-2018/09-04-2018
Test location : Terborg, The Netherlands

Relevant Normative Documents

NEN-EN-IEC 61442:2005
CENELEC HD 629.1 S2:2006

Test performed

Type test following CENELEC HD 629.1 S2:2006, Table 10, additional tests for smallest and largest cable cross section compliance

Test result

The test object meets the requirements of test series additional tests. Defined in normative documents above.

PASSED

Author:
Marco van Helmond
Test engineer

Terborg, 10/04/2018

Agree:

Dennis Bergsma
Product Development Manager