
Test specifications

Test object : LoviSil® Transition joint
Type : M(R)105
U₀ / U (U_m) : 12/20 (24)kV
Rated cross-section range : Three core up to 500 mm² Transition
Manufacturer : Lovink Enertech B.V.
Test period : 12-2023 / 02-2024
Test location : Terborg, The Netherlands

Relevant Normative Documents


NEN-EN-IEC 61442:2005-04
CENELEC HD 629.2 S2:2006-02

Test performed

Type test following CENELEC HD 629.2 S2:2006-02, Table 4 (I B1)

Test result

The test objects met all the requirements defined by CENELEC Harmonization document HD629.2 S2:2006-02. The test objects therefore passed all tests without any breakdown or damage.



Author:

J. Conradie

Development & Test Engineer

Terborg, 14-02-2024

Accepted:

D. Bergsma

Product Development Manager

Terborg, 14-02-2024

